

Letter:- 182 dated- 08/03/2026

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report

DISTRICT - VAISHALI

DIVISION - HAJIPUR

Sample Collected by:- School staff

Month:- March 2026

DIVISION - HAJIPUR						Sample Collected by: School staff														Month: March, 2026				
Sl No	Block	Panchayat	Village	Name of Habitation	Location of Source	Parameters																Report Made Over 15 Days After On req	Remarks	
						pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	AL	Fe	Mn	SO ₄	F	As	Fluoride	Remarks made on it compared to Source		Date Carried on	
1	Bidupur			Shitalpur Kaimalpur Bidupur Hajipur	Happy Mind Academy	7.2	1.0	279	133	109	25	11	23	113	.	.	.	0.1	.	1.09				
Permissible limit in absence of alternative source						6.5-8.5	1.0	.	500	200	75	30	250	200	0.3	45	200	1.0	0.01					
						NA	5.0	.	2000	800	200	100	1000	500	1.0	HR	400	1.5	HR	.	.	.	.	
						Unit	NTU	mc/s	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l				

PH Division Hajipur
08/03/2026

Chemist
PH Division Hajipur
08/03/2026



Manager
HAPPY MIND ACADEMY
BIDUPUR (VAISHALI)